

MEMORANDUM

To: Michael Harrington, Insurance, Health, Environment,
Buildings & Grounds Chair
Robert Kosin, Village Administrator

850 Forest Edge Drive, Vernon Hills, IL 60061
TEL 847.478.9700 ■ FAX 847.478.9701

From: Daniel J. Strahan, P.E., CFM
Gewalt Hamilton Associates (GHA)

820 Lakeside Drive, Suite 5, Gurnee, IL 60031
TEL 847.855.1100 ■ FAX 847.855.1115

www.gha-engineers.com

Date: September 19, 2014

Re: Board of Health Meeting- Tuesday, September 9th, 2014
22 Spring Lane Variance

On Tuesday, September 9th, 2014 the Board of Health met to consider a variance application for a septic system at 22 Spring Lane. The meeting was attended by Chairman Gwynne Johnston, Frank Konicek, M.D., and Anne Majewski, M.D. Technical information for the septic system design was presented by the applicant's engineer, Peder Finnberg of Heritage Land Consultants.

A permit to replace the existing septic system at 22 Spring Lane was received on August 19, 2014 and reviewed by GHA. In order to meet the required 24" vertical separation from the limiting layer, the septic design engineer proposed a Type V mound septic system. As the Village Code does not include design criteria for this type of system, the system was designed in accordance with Lake County septic design standards and a variance was requested.

Upon review and consideration of the documents, the Board approved a variance to allow the mound septic system at the property in question.

cc: Board of Trustees