Electric Service Upgrade





Permit Application.
\square All construction shall comply with the adopted building codes and ordinances.
\Box A legible survey or site plan indicating the location of the proposed pedestal, panels, overhead service drop or lateral trench with depth.
☐ Electric Load Calculations with panel schedules.
\square Single line diagram with wire sizes, panel/breaker size & grounding detail.
Bonding of the water pipe system at the water meter & water heater(s). The water heater(s) shall be jumpered between the cold and hot water pipes with a jumper sized according to NEC Table 250.66, per NEC 25.104(A)(1); and any metal gas piping shall be bonded, per NEC 250.104(B).
Proper clearances for the electric panels shall be maintained per NEC 110.26.
\Box All smoke alarms and CO alarms are required to be up to date and in proper working order.